

JB

Water & Sampling

JB Water & Sampling

P. O. Box 610

Niles, MI 49120

(269) 845-1445

jb@jbwater.me

TEST SAMPLE # 170337
Date/Time Sampled: 8/6/2020 9:15:00 AM
Date/Time Received: 8/7/2020 8:00:00 AM
Tap Sampled: Raw Sample Tap
Sampled By: JBG
EVALUATION # 10113
SITE NAME: Riverside School #5
LOCATION TESTED: 4439 River Road
SAMPLE ID: Routine
COUNTY: Berrien

WSSN#
2016911

TEST RESULTS

Result Key
VIOLATION
AT CONTAMINATION LIMIT
PASSING

PHYSICAL PARAMETERS	RESULT	MCL
pH	7.8	6.5 - 8.5 SU
Temperature	10.3 ° Celcius	
Chlorine Residual	0 mg/l	
Sample Source	Type II	

BACTERIA	RESULT	METHOD
Coliform	Not Tested	Colilert Presence/Absence
E. Coli	Not Tested	Colilert Presence/Absence

CHEMICAL TEST	LEVEL	METHOD	MCL	NOTE
Nitrate	0.53 mg/l	Hach 10206	10.0	Received on ice
				Acidified 8/7/20
				Analyzed on 8/10/20 at 2:10PM

* The water analysis contained in this report was performed by Your Environmental Services, LLC, Mishawaka, IN.

Analyzed By: Carla Snow

Jordan Garrett
Laboratory Director

Carla S. Snow
Lead Laboratory Technician

Report Issued On: 8/10/2020

Indiana Certified Laboratory - Microbiology: M76-06/Chemistry: C71-04
Michigan Certified Laboratory - Microbiology/Inorganic Chemistry: 9995