


	<b>Laboratory Testing Report</b>												
	<b>Call or Text US</b> <b>(833) YESLABS, (833) 937-5227</b>				<b>Email Us:</b> <b>orders@yeslabslc.com</b>				<b>Find us on the Web</b> <b>WWW.YESLABSLLC.COM</b>				
<b>Property Location Information</b>	<b>Property:</b> River School #5			<b>Address:</b> 4439 River Road			<b>City:</b> Sodus		<b>State:</b> Michigan		<b>Zip Code:</b> 49126		
<b>General Information</b>	<b>Client:</b> JB Water & Sampling				<b>Sample Source:</b> Community Water Source				<b>Sampled By:</b> Water Operator			<b>Initials:</b> JBG	
<b>Compliance Details</b>	<b>System:</b> Type 2						<b>PWSID #:</b>			<b>WSSN #:</b> 2012111			
<b>Date / Time Received</b>	06-23-2023 09:24 AM						<b>County:</b> Berrien County			<b>Well Permit #:</b>			
<b>Test Results</b>													
<b>Sample Number</b>	<b>Eval Number</b>	<b>Sample Type</b>	<b>Sample Location</b>	<b>Test Performed</b>	<b>Test Result</b>	<b>Result Pass / Fail</b>	<b>Date / Time Sampled</b>	<b>Date / Time Started</b>	<b>Date / Time Analyzed</b>	<b>Method</b>	<b>Unit of Measure</b>	<b>MCL</b>	<b>AL</b>
236016		Routine	Kitchen Sink	Total E.coli	Absent	P	06-22-2023 09:21 AM	06-23-2023 11:55 AM	06-24-2023 12:36 PM	SM 9223 B - Colilert	per 100 mL	0.000001	
236016		Routine	Kitchen Sink	Total Coliform	Absent	P	06-22-2023 09:21 AM	06-23-2023 11:55 AM	06-24-2023 12:36 PM	SM 9223 B - Colilert	per 100 mL	0.000001	
<b>Edgar Ramos</b> Laboratory Manager					<b>Carla Sue Snow</b> Laboratory Technician					<b>Ellie Highland</b> Laboratory Technician			
Your Environmental Services, LLC, 4609 Grape Road, STE D5, Mishawaka, Indiana 46545 Indiana Microbiology Certification: M-76-06, Indiana Chemistry Certification: C-71-04, Michigan Microbiology/Inorganic Chemistry Certification: 9995										<b>For Assistance Interpreting Your Report Results</b> <b>Please visit our website: WWW.YESLABSLLC.COM</b>			